PATONS LANE RRC
RESOURCE RECOVERY CENTRE

SURFACE WATER MONITORING REPORT – DEWATERING EVENT*

*** via LDP2 (HES)**

February 3, 2021

Rainfall: 35 mm (72 h prior to sampling)
Sampled within 24 h of discharge: Yes
Horiba U-52 Calibrated: Yes

Table 1: NSW EPA Licensing Requirements (No. 20814 – 20/8/2019) - Special Frequency 1[a]

Parameter	Units	Analytical Detection Limit (Laboratory LOR)	S7 Blaxland Creek	LDP2 (HES Gantry)	LDP2 (HES Spillway)	S8 Blaxland Creek	EPL 100th percentile concentration limit	National Water Quality Guidelines[b]
pH		Field Probe	6.92	7.79	7.76	6.83	6.5−8.5	6.5−8.5[c]
Total Suspended Solids	mg/L	5	93	12	8	73	50	6−50[c]
Ammonia (as N)	mg/L	0.01	0.02	0.01	0.04	0.02	1.0	0.9 (pH 8.0) Varies with pH[d]
Electrical Conductivity (EC)	µS/cm	Field Probe	207	1120	1130	225	NSL[e,f]	125−2200[c]
Total Dissolved Solids	mg/L	1	278	654	660	283	NSL	NGV[g]
Dissolved Oxygen	% Saturation mg/L	Field Probe	62.0 5.45	67.1 5.60	67.0 5.62	68.7 6.05	NSL	85−110%[c]
Total Organic Carbon	mg/L	1	15	4	4	15	NSL	NGV
Potassium	mg/L	1	4	6	5	4	NSL	NGV

[a] Values for pH and dissolved oxygen represent the mean of three independent measurements at each sampling site. All other parameters are based on a composite grab sample of surface water 10−30 cm depth).

[b] ANZECC and ARMCANZ (2000).

[c] Applicable to coastal lowland rivers.

[d] Refer to Tables 8.3.6 and 8.3.7 of ANZECC and ARMCANZ (2000) to determine the guideline value based on site-specific pH and temperature.

[e] NSL, no specific limit.

[f] Recommended limit of 1600 µS/cm for discharge to Blaxland Creek (or off-site).

[g] NGV, no guideline value.